

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:119 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADT Security Service, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Models SIGA-IO, SIGA-MIO Input/Output Modules and SIGA-RMI and SIGA-MRMI Riser Monitor Modules. Models SIGA-IO, SIGA-MIO Input/Output Modules monitors contact type devices. SIGA-RMI and SIGA-MRMI Riser Monitor modules monitors 24Vdc circuits, 25V and 70V audio circuits, and telephone riser signals. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed EST-3 fire alarm control unit (CSFM Listing No. 7165-1591:186 and 7170-1591:187).

XLF: 7300-1591:210

11-07-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 2, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager